

IEQ SCHOOL DATA BASE									
School Name: Mount View Middle School		Principal: Allen Cosentino		DATE: January 3, 2017					
IEQ Team Leader: Kimberly Hess		IEQ System Leader: Greg Meciulla							
LOOK-FORS	ROOM/LOCATION	COMMENTS	ADMIN	FACILITIES	WORK ORDER NUMBER of POTENTIAL IEQ	DATE ASSIGNED	COMPLETION DATE	30 DAY REVISIT	CLOSED
1. No unusual or offensive odors, or temperature discomfort	15 - 21 - 8 - 2 - 1	15: HVAC cold - 21: HVAC temp cool off in PM - 8: Closet is very cold - 2 - cold air blowing - 1: cold inside the closet		x	19874		2/2/17		
2. No Air Fresheners	Custodial Office	Custodial Office: air fresheners	x				2/6/17		
3. No food, dirty lunch boxes, etc. left in room	9- 4A -Guidance- Tech Ed	9: Need to put food in containers - 4A: put food in containers-Guidance: put food in containers-Tech Ed: food needs to be in containers	x				1/13/17		
4. Vents are clean and unobstructed	Art-School store - Office Bathroom - Building Services 2 closet by Bandos - Staff Bathroom by Parson - FACS - Electronics Room 2 - Science 2 - 9 -Staff Lounge -Kitchen - Cafeteria - Electrical Closet across from Staff Lounge -19	Art-clean the vent by the front door, keep HVAC vent clear - School Store: Dust the vent - Office Bathroom: clean the vent - Building Services 2: Clean the vent- Staff Bathroom: clean the vent - FACS: clean the vent about station 1 - Electronic Room 2: Clean vent: Science 2: Clean vent - 9: keep HVAC unit uncovered and unblocked- Staff Lounge: HVAC vent in back is closed - Kitchen: Bathroom vent dirty and non-functional, vent is unclean in dishwashing room - Cafeteria: return vent on wall near side of stage needs to be cleaned - Electrical closet: clean vent - 19: Keep AC unit clear		x			2/8/17		
5. Temperature sensors are not blocked									
6. Area appears clean and dust free	Hall by Health Room - Hall outside FACS room - Science 5 - 1 - Science 2 - 8 - 9 - 9A - Science 3 -Media Production - Guidance	Hall by Health Room: dust top of bulletin board and window sills - Hall outside FACS room: molding needs dusting - Science 5: clean the heater - 1: Closet is too messy - Science 2: clean eye wash - 8: dust window sill - 9: Clean out cabinet (no sprays)- 9A: dust back of TV - Science 3: Clean eye wash - Media Production: shelving needs dusting - Guidance: dust shelf tops -		x			2/1/17		

IEQ SCHOOL DATA BASE									
School Name: Mount View Middle School		Principal: Allen Cosentino		DATE: January 3, 2017					
IEQ Team Leader: Kimberly Hess		IEQ System Leader: Greg Meciulla							
7. No signs of animal infestation	Stairwell by Bando (1) - Stairwell by Ammann (8) - 9	Stairwells: Lights have bugs in them, find the source and clean the lights. - 9: Bugs in the light in the closet.		x		15248		Put in 1/30	
8. Ceiling tiles present; no broken, stained, or painted	Art - Hall above locker 660/661 - School store- Health Room - 5 - Outside Science 3 - FACS - Science 1 - 2 - Outside main office - 1- Staff Workroom - 10 - 16 - 19 - 21 - 20- Hall by 22A - Hall by elevator - Media Dark Room - Staff Lounge - Hallway outside staff lounge - Parks and Rec - Chorus Room- Tech Ed- Storage by Boiler Room - Kitchen - Cafeteria - Kenny's Office	Art: leak above Kiln- Hallway: painted ceiling tile - Store: 2 broken ceiling tiles - Health: 2 ceiling tiles in front bedroom - 5: stained ceiling tile about teacher desk - Sci 3: Stained ceiling tile in hallway - FACS: stained ceiling tile about big cabinets, gap in ceiling molding , ceiling tile outside prep closet - Sci 1: stained ciling tile at front of room - Sci 5: ceiling tiles in closet need better cuts some need to be replaced or cleaned and need another grid piece, corner ceiling molding by window - 2: stained tile by window - Outside main office entrance door and prep room door: wet tiles - 1: Closet has a stained tile- Staff Workroom: Stained ceiling tile - 10: ceiling corner L - 16: ceiling tile speaker warped and falling out- 19: Ceiling tiles above AC are caving in (replace)- 21: saggin ceiling tiles - 20: Corner ceiling grid outside corner - Hall by 22A: ceiling tile needs adjusting or replacing - Hall by elevator: ceiling tile stained - Dark Room: stained ceiling tile by center light, cracked tile by sink, -Staff Lounge: small closet in back of room there are no ceiling tiles, it opens directly to attic - Hallway outside staff lounge: water damage tile before fire door on left, water damage tiles just after fire door on left.- Parks and Rec Room: damaged tile by entry door, cracked tile near door, stained tile above window, cracked tile in corner, in the storage room there is a chipped ceiling tile. - Chorus Room: water damaged tile on right, cracked ceiling tile in hallway outside of room - Tech Ed Storage Rooms: in the middle storage room there is a water damaged ceiling tile, left storage room there is a water damaged ceiling tile - Storage by boiler room: active leak per wet ceiling tile - Kitchen: multiple ceiling tiles are warped and need to be replaced or refit, missing ceiling tile above sink in main kitchen with a hose coming from it, dishwashing room there is a tile pulled back or missing.- Cafeteria: chair storage room, vent tile has water damage, front left tile is damaged, multiple chiped tiles in ceiling in center of cafeteria, multiple tiles appear to be askew - Kenney's office: ceiling tiles not fitting properly		x		20719		2/10/17	
9. Walls show no signs of water damage/mildew/ paint irregularities	Science 4 -Media by GT Room - Custodial Closet Across from room 14	Science 4: The paint on the ceiling window is chipped -Media: drywall by the GT room needs to be repaired. - Custodial Closet: clean out and need block filler		x		20722		2/10/17	
10. No condensation or other evidence of humidity on ceilings, walls, doors, etc.	Media Center	Media center: roof leak media skylight by atrium in front of media storage, ceiling above book shelves, fiction side.		x		20723		2/10/17	
11. Limited use of non-issued HCPSS furniture and appliances	Art - Health Room - Principal's office - Staff Workroom - Science 1 - Resource 1 - 1 - Science 2 - 4A - Science prep - 8 - 9 - 9A - Science 3 - Staff Lounge - Custodial Office - Boy's Locker Room - PE Office- Parks and Rec Room - 13 - 14 - 15 - 16- 22A - 23 - 24- 25- Guidance	Art: microwave, coffee maker - Health Room: extra microwave - Principal's office: fridge and coffee maker - Staff workroom: Kurig - Science 1: Christmas lights - Resource 1: Coffee maker, lamp - 1: Coffee maker in cabinet - Science 2: too many figurines - 4A: Christmas lights, bunny lamp, lava lamps, too many personal items - Science Prep: too many microwaves, coffee makers - 8: remove the rug and lights from the closet, too many figurines on window sill - 9: remove non-HCPSS issued lamp, remove microwave and fridge from the bathroom - 9A: Christmas lights, lamp - Science 3: unplug green lamp or put in a bulb, remove lamp on file cabinet - Staff Lounge: couch, pillows - Custodial Office: microwave - Boys Locker Room: fridge in towel storage room - PE Office: microfridge, microwave - Parks and Rec Room: floor fans- 13: Non-HCPSS bookshelves - 14: non-HCPSS Bookshelf- 15:non-HCPSS Bookshelf, radio - 16: Non-HCPSS bookshelves- 22A: Chrismas lights - 23: non-HCPSS shelves- 24: non-HCPSS shelf unit - 25: remove cabinet glass unit - Guidance: Refrigerator, fan, microwave, candles, non-HCPSS issued lamps, candles		x				1/13/17	
12. No excessive fabric materials, stuffed animals, beanbags, pillows, etc.	Health Room - Office - AP office - Science 1 - Resource 1 - 4 - 4A - 8 -PE Girl's office -13 - 17- 21 - 22A - Guidance	Health Room: too many stuffed animals - Office: Fake flowers - AP Office: fake flowers - Science 1: Fake flowers - Resource 1: fabric on desk, fake flowers - 4: fabric on desks - 4A: stuffed animals - 8: put fabric props in plastic containers (closet), fake plants - PE Girl's Office: stuffed animals, fabric over cabinet- 13: curtains under sink, valances - 17: Curtains over window - 21: Curtains - 22A: football flag - Guidance: trees, stuffed animals, bean bags, cushions on rocking chairs,		x				1/13/17	

IEQ SCHOOL DATA BASE		
School Name: Mount View Middle School	Principal: Allen Cosentino	DATE: January 3, 2017
IEQ Team Leader: Kimberly Hess	IEQ System Leader: Greg Meciulla	
<p>Boys Bathroom by Room 8: There seems to be an issue with the HVAC unit above the bathroom ***Fire extinguisher needs a new tage in Science 5(COMPLETED 1/30/17) ***Clean off top shelf so that it is at least 18 inches from the ceiling: teacher workroom, storage closet in workroom, FACS, FACS closet, 1 closet, 8 closet, staff lounge, chorus room, PE towel storage room, laundry room, Girl's locker room towel storage room, PE office, Kenney's office, PE big storage room, 13, 13 closet, guidance records room ***Noisy HVAC in the Art Room ***Noisy HVAC from the previous day in the Band room- reported to use during the walkthrough. *FACS Room: keep computer cart 3 feet away from electrical panel. ***Grounded breakders and/or Extension Cords: FACS, Staff lounge, Stage, ***Sprinkler Head Issues: Sprinkler in hall outside science 1, sprinkler needs a cover in science 5, hallway by room 9, Science 3 above presentation desk, Staff Lounge there are two sprinklers that need attention, boy's locker room, (COMPLETE 2/7/17) ***Kitchen: Missing panel exposing electrical wiring on unit under the dishwasher (COMPLETED 1/30/17) **HVAC unit missing its cover in room 20, FACS, 1, Room 3, Room 6,</p>		